



FREE-FLOW CAPACITY: 2.920 GPM [0.1842 L/S] MINIMUM - 214.7 GPM [13.55 L/S] MAXIMUM

FLOW →

Ha POINT OF MEASUREMENT



PLAN VIEW



ELEVATION VIEW



REV	REVISION DESCRIPTION	BY	DATE

NOTES:
⚠ NOT FOR USE ON SANITARY FLOWS
1) FLOW IS FROM LEFT TO RIGHT
2) ALL HARDWARE TO BE STAINLESS STEEL
3) ANCHOR CLIPS AND PULTRUDED FRP TOP STIFFENING ANGLES
4) MINIMUM FRP LAMINATE THICKNESS IS: 1/4" [0.635 CM] WITH 30% GLASS CONTENT AND 15 MIL (MIN.) GEL COAT WITH U.V. INHIBITORS

This drawing and the data contained within is the sole, confidential property of OPENCHANNELFLOW (OCF) and may not be copied, reproduced, disclosed to others, in whole or in part, without the prior written consent of OCF. OCF reserves the right to change any dimension, finish, material, or method of construction indicated on this drawing at will and without notice. This drawing is provided in confidence with the understanding it shall be returned to OCF upon demand.

OPENCHANNELFLOW		
DWG NO.	P-F-2-N-N-N-N-N-N	DATE 10.11.04
FIBERGLASS 2" PARSHALL FLUME		
Unless otherwise indicated, dimensions are in feet and inches, with centimeters indicated in []. Angles are in degrees.		

